



CE Certification for Mercury Security products

The products listed below meet CE specifications. Testing and verification was performed by an independent laboratory and test reports are on file at Mercury Security.

SCP-C, EP2500, EP1502
MR50, MR52, MR16in, MR16out
MR-DT, MUX8, MUX-4iso
MR51e, EP1501

Test Specifications:

EMI and EMC requirements European standards:

EN 61000-6-4, EN 61000-3-2, EN 61000-3-3, and EN50130-4

EN 61000-6-4 is a generic emissions standard which references the following information technology equipment emissions specification: EN 55022


EN 61000-3-2 is a harmonic current emissions standard for equipment with input current up to 16A per phase.

EN 61000-3-3 is a voltage fluctuation and flicker emissions standard for equipment with rated current less than or equal to 16A.

EN 50130-4 is a product family EMC standard that references the following specifications:

- IEC 61000-4-2, IEC 61000-4-3, IEC 61000-4-4, IEC 61000-4-5, IEC 61000-4-11
- and ENV 50141

Place: Long Beach, CA
Date: March 17, 2011



Hing Hung

VP- Operations